


NEYSLUVATNSLAGNIR: STÆRDIR.
 1 STÚTUR: DN15
 2-4 STÚTUR: DN20
 5-12 STÚTUR: DN25
 13-25 STÚTUR: DN32
 26-50 STÚTUR: DN40
 51-175 STÚTUR: DN50



LYKILMYND

Verkfræðistofa Hauks Ásgeirssonar e.h.f.
 Brautarholt 10-14, 105 Reykjavík
 Sími: 534-8815 897-8132
 e-mail: haukur@vha.is
 www.vha.is
 Kennitala: 560600-3050

VHÁ

Hannað H.Á.	Teknað H.Á.	Samþykkt: Kennitala 301255-4629
----------------	----------------	------------------------------------

HRUNAMANNAVEGUR 3-5
 FLÚÐUM
 LAGNIR
 GRUNNMYND NEYSLUVATNSLAGNA
 OG LOFTRÆSILAGNA KJALLARA

Mkv. 1:50	Teikn. nr. 3-1.1	Verk nr. 2340
--------------	----------------------------	-------------------------

Antunarsamningur / hönnunarskjórnir: A
 Útgáfa Dags: JÚL'17