



Byggt á málupprættum
 Dags. 17.12.2020
 útg. 03



EXECUTION CLASS EXC3 IN PRODUCTION

WELDING: ALL WELDINGS MUST BE AT THROUGH PENETRATION, CONTINUOUS, WITHOUT SLASHES, UNIFORM.

TIGHTENING TORQUE

SCREW DOWN THE BOLTS WITH DYNAMOMETRIC KEY WITH TIGHTENING TORQUE ACCORDING TO FOLLOWING TABLE (N·M)

BOLT diameter	12	16	20	22	24	27	30	36
Material 10.9 class	10	25	45	65	80	125	165	200
Material 8.8 class	10	20	35	50	60	90	120	150

50% Mv given by deliver

- All dimensions without units are given in mm. Elevation heights are given in m.
- All drawings and elevation heights in existing building, have to be confirmed on site.
- Construction drawings are obligated to be considered with technical report and other construction drawings.
- All changes in building construction on execution level are obligated to be considered with design engineer.
- All dimensions and elevation heights should be confirmed on site before starting construction work.
- RF AND CONCRETE WORKSHOP (e.g. FOUNDATIONS, FOOTINGS, ANCHORS) - OUT OF THIS DOCUMENTATION

CONTRACTOR	NORVIK PRÁTAKA PROJEKTIVA KONSTRUKTÍVA BÚÐVAERÐI HEYRIS PRÁKTUNAR		/ DESIGN OFFICE JONSTOKA PROJEKTÖRUMANA PRÁKTAKA PROJEKTIVA KONSTRUKTÍVA BÚÐVAERÐI HEYRIS PRÁKTUNAR
PROJECT NAME	Tengivirkni Lækjartún – Byggingarvirki		
	Lækjartún II Tengivirkni 851 Hella		
PHASE	EXECUTIVE DOCUMENTATION - WORKSHOP DRAWINGS		
DESIGNED	mgr. in2. Tomasz Bartkowiak		
CHECK	BYVP/97 spec. konstrukcyjno-budowlana		
DRAWING NAME	01. TERMINAL / Tengivirkni	DRAWING NO.	2345-084-140-05
	ASSEMBLY		2020.091.01.1005
	SECTION IN AXIS	SCALE:	1:25
	A.D.	REV:	A0
DATE	POZNAŃ 2020-11-09	SHEET:	A0

Yfirfarið og samþykkt 16.02.2021

EFLA
 VERKFRÆÐISTOFA
 Sími: 412 6000 www.efla.is

Guðmundur Hjálason kl. 070986-5579

STEEL INSIDE : S235JR (C-2H)
STEEL OUTSIDE : S355J2 (HOT DIP GALV)
SCREWS CLASS: 5.8,8.8,10.9HV