



Brekkugerði 1.hæð

Varmatap, ofnaskrá – Samantekt

Herbergi	Heiti	Rými nr.	Sloufa nr.	Gólfefni	Varmatap W	Varmatap Kcal/klst	atnsmag l/s	Valinn ofn h=600	Ofn nr.	Þéttleiki mottu í d mitt gólf við glugga	Slöngulengd samtals m	Varmagjöf W
Anddyri stofa íbúð húseiganda	101	1-2	Flísar	2232	1919	0,089				100	75	2251
Herbergi íbúð húseiganda	102			535	460	0,005	11-1200	1.02				881
Bað/þvottur íbúð húseiganda	103	3	Flísar	276	238	0,022				150	75	544
Vinnuherbergi íbúð húseiganda	104			405	349	0,003	11-800	1.04				587
Salerni miðrymi	105			298	256	0,003	11-800	1.05				587
Móttaka miðrymi	106			959	825	0,004	11-1000	1.06 a				734
Móttaka miðrymi	106					0,029	11-1000	1.06 b				734
Anddyri	107			300	258	0,003	11-800	1.07				587
Samþingilegt þvottahús	108			262	225	0,003	11-800	1.08				587
Eldhús 1. hæð	109	8	Flísar	1130	972	0,011				200	105	1825
Baðherbergi starfsmanns	110			464	399	0,004	11-900	1.10				660
Íbúð starfsmanns	111			873	750	0,008	11-1800	1.11				1320
Sólskáli		4-5		1500		0,060				100	100	1520

Samtals 7.734 6.651 0,09 521 12.817

Framrás ofna 85°C dT 40 °C Framrás gólfhita 45°C dT 6 °C

Brekkugerði 2.hæð

Varmatap, ofnaskrá – Samantekt

Herbergi	Heiti	Nr	Sloufa nr.	Gólfefni	Varmatap W	Varmatap Kcal/klst	atnsmag l/s	Valinn ofn h=600	Ofn nr.	Þéttleiki mottu í d mitt gólf við glugga	Slöngulengd samtals m	Varmagjöf W
Baðherbergi	201				227	195	0,0035	11-800	2.01			587
Baðherbergi	202				182	157	0,0035	11-800	2.02			587
Herbergi	203				1010	869	0,0087	11-2000	2.03			1467
Gangur	204				492	423	0,0052	11-1200	2.04			881
Herbergi	205				685	589	0,0061	11-1400	2.05			1027
Baðherbergi	206				244	210	0,0035	11-800	2.06			587
Baðherbergi	207				129	111	0,0035	11-800	2.07			587
Herbergi	208				671	577	0,0061	11-1400	2.08			1027
Herbergi	209				901	775	0,0083	22-1000	2.09			1402
Setustofa	210				892	767	0,0044	11-2000	2.10a			734
Setustofa	210						0,0044	11-2000	2.10b			734
Herbergi 6	211				901	775	0,0079	11-1800	2.11			1320
Herbergi 7	212				1074	924	0,0087	11-2000	2.12			1467
Gangur	213				145	125	0,0035	11-800	2.13			587
Herbergi 8	214				1083	931	0,0061	11-1400	2.14a			1027
Herbergi 8	214						0,0035	11-800	2.14b			587
Baðherbergi	215				92	79	0,0022	11-500	2.15			367
Baðherbergi	216				235	202	0,0035	11-800	2.16			587
Herbergi	217				563	484	0,0052	11-1200	2.17			881
Baðherbergi	218				298	256	0,0035	11-800	2.18			587
Stigagangur	219				444	382	0,0039	11-900	2.19			660

Samtals 2.596 8.830 0,11 0 17.690

Framrás 85°C dT 40 °C



www.verkis.is - sími: +354 422 8000

SAMBÝKKT: VERKÍS Ari Guðmundsson 150773-5554

B 2015-11-20 Breyting AJ AJ KME ArG

A 2015-11-09 Verktelkning AJ AJ AAA ArG

ÚTG DAGS SKÝRINGAR TEIK HANN RÝNT SAMP

BREKKUGERÐI
 AUSTURBYGGÐ 20, LAUGARÁSI 801 SELFOSS
 Ofnatöflur.
 1. og 2. hæð

6970

VERKFANG 15222 TEIKNING M43.001 B