



GÓLFHITASKRÁ (DEILIKISTA #3)

| SLAUFNA | c/c | AFKÖST | l | STÆRD | AFKÖST | q | HITASTIG Í RÝMI | HITANEMI | OPNUN |
|----------------|------|---------------------|--------------|-------------------|---------------|--------------------|-----------------|----------|------------|
| NR. | [mm] | [W/m ²] | m | [m ²] | [W] | l/min | [°C] | Í RÝMI | STILLILOKA |
| 201 | 150 | 73,6 | 62,0 | 9,3 | 684 | 1,42 | 20 | T1 | 56 % |
| 202 | 100 | 73,6 | 77,0 | 7,7 | 567 | 1,17 | 20 | T1 | 52 % |
| 203 | 100 | 100,3 | 58,0 | 5,8 | 582 | 1,20 | 20 | T2 | 47 % |
| 204 | 150 | 86,4 | 87,0 | 13,05 | 1128 | 2,33 | 20 | T3 | 100 % |
| 205 | 150 | 65,0 | 89,0 | 13,35 | 868 | 1,79 | 20 | T4 | 80 % |
| 206 | 100 | 73,6 | 68,0 | 6,8 | 500 | 1,04 | 20 | T1 | 36 % |
| 207 | 100 | 100,0 | 100,0 | 10 | 1000 | 2,07 | 20 | T1 | 96 % |
| SAMTALS | | | 541 m | | 5,3 kW | 11,02 l/min | | | |

GÓLFHITASKRÁ (DEILIKISTA #4)

| SLAUFNA | c/c | AFKÖST | l | STÆRD | AFKÖST | q | HITASTIG Í RÝMI | HITANEMI | OPNUN |
|----------------|------|---------------------|--------------|-------------------|---------------|-------------------|-----------------|----------|------------|
| NR. | [mm] | [W/m ²] | m | [m ²] | [W] | l/min | [°C] | Í RÝMI | STILLILOKA |
| 201 | 150 | 65,0 | 34,0 | 5,1 | 332 | 0,69 | 20 | T2 | 58 % |
| 202 | 100 | 73,6 | 63,0 | 6,3 | 464 | 0,96 | 20 | T3 | 91 % |
| 203 | 100 | 73,6 | 69,0 | 6,9 | 508 | 1,05 | 20 | T3 | 100 % |
| 204 | 100 | 73,6 | 66,0 | 6,6 | 486 | 1,00 | 20 | T3 | 96 % |
| 205 | 100 | 100,0 | 41,0 | 4,1 | 410 | 0,85 | 20 | T4 | 71 % |
| SAMTALS | | | 273 m | | 2,2 kW | 4,55 l/min | | | |

OFNASKRÁ

| Ofn nr. | Gerð | Stærð [mm] | Afköst [W] | Ofnlokar | A B C D |
|-------------------------------|------------|-------------|------------|-----------|---------|
| 201 | Ofnagryfja | 70x200x1500 | 1744 | Mótorloki | A - B |
| 202 | Ofnagryfja | 70x200x1500 | 1744 | Mótorloki | A - B |
| 203 | Ofnagryfja | 70x200x1500 | 1744 | Mótorloki | A - B |
| HEILDARAFKÖST [W] 5232 | | | | | |

ÁRITUN AÐALHÖNNUÐAR: *Guðfjörður Þorgeirsdóttir* KT. *c.2024.03.15*

| | | | |
|-----|-------|----------|-------|
| BR. | DAGS. | BREYTING | SAMP. |
| | | | |



HVÍTÁRBRAUT 19 ÖLFUSSI
FRÍSTUNÐARHÚS
GÓLHITI
GRUNNMYND 2. HÆÐ

| | | | |
|--|-----------------|--------------------------------------|--------------|
| SAMPYKKT: | | KT. <i>Guðfjörður Þorgeirsdóttir</i> | |
| HÖNNUÐUR | YFIRFARIÐ | DAGS. ÚTG. | DAGS. BREYT. |
| GP | gummi@ferill.is | HPV | 25.02.13 |
| MKV. | VERKNR. | TEIKN. NR. | BREYT. |
| 1:50 | 12101 | 3-202 | |
| Ferill ehf. Mörkín 1. 108 Reykjavík Sími: 575 1600 Fax: 575 1601 www.ferill.is | | | |