



STEINSTEYPA

STEYPA ER C25/30 MED A.M.K. 300 Kg SEMENT í m³.

LOFTINNHÁLD STEYPU V/S-TALA (UMHVERFISFLOKKUR 2b) : 6-8 %

SIGMÁL STEYPU (S2) : < 0.55

MESTA STEINASTÆRD : 50 - 90 mm

TITRA SKAL ALLA STEYPU. : 32 mm

STEYPUHULA Á JÄRNUM

GILDIN EIGA VID UM VENJULEGAR ADSTÆÐUR, EF ANNAD ER EKKI SÝNT Á TEIKNINGUM. ÞAR SEM TÆRINGARHETTA ER MIKIL GILDA ADRAR REGLUR UM STEYPUHULU JÄRNA.

	PLÖTUR	VEGGIR	BITAR	SÜLUR
INNANHÜSS	15	20	20	20
UTANHÜSS	25	25	25	25
SÖKKLAR	35	35	35	35
STEYPT AD JÖRD	50	50	50	50

UM BITA OG SÜLUR GILDIR EINNIG: C1 ≥ 1.5xd

STEYPUSTYRKARSTÁL

STÁLGEÐI: K - KAMBSTÁL fyk = 500 Mpa

BEYGING STÁLS d = ALLIR SVERLEIKAR

SKEYTING BENDISTÁLS ER SAMKVEMT EFTIRFARANDI: D = 5 x d

PVERMÁL STÁLS, d í mm	10	12	16
SKEYTILENGD í mm	500	600	800

LÁRÉTT JÄRN SEM KOMA Í HORN EDA PVERVEGG SKAL BEYGJA SKEYTILENGD FYRIR HORN.

BENDING Í SÖKKULVEGGI

2 K12 EFST OG NEDST

K10 c/c 250 LÖDRÉTT

K10 c/c 300 LÁRÉTT.

MÁL ERU Í mm NEMA ANNARS SÉ GETID.

VERKFRÆÐISTOFA ARBORGAR ehf
 AUSTURVEGI 69 800 SELFOSSI
 Sími 480 4800 FAX 480 4801
 www.verkarborg.is verkarborg@verkarborg.is

SGHUS
 AUSTURVEGI 69 800 SELFOSSI
 Sími 482 3850 FAX 482 3851
 NETFANG sghus@sghus.is
 VEFANG www.sghus.is

MIDENGI Nr.7 GRÍMSNESI

BURDARVIRKI: MKV: 1:20

SNID Í SÖKKUL: MKV: 1:20

SKÝRINGAR OG GRUNDUN: MKV: 1:50

HANNAÐ: T. ELLERT TÓMASSON TEIKNAD: LAURA APARISI

VERKNÚMÉR: 6800 SKRÁRNAFN: 6800_bv-U1.dwg

DAGSETNING: SAMÞYKKT: TEIKNING NÚMÉR: 202

14.12.2006 201170-3979