



STEINSTEYPA
STEYPA ER C25/30 MED A.M.K. 300 Kg SEMENT l m³.

LOFTINNIHALD STEYPU : 6-8 %
V/S-TALA (UMHVERFISFLOKKUR 2b) : < 0.55
SIGMÁL STEYPU (S2) : 50 - 90 mm
MESTA STEINASTÆRD : 32 mm
TITRA SKAL ALLA STEYPU.

STEYPUHULA Á JÄRNUM
GILDIN EIGA VID UM VENJULEGAR ADSTÆÐUR, EF ANNAD ER EKKI SYNT Á TEIKNINGUM. ÞAR SEM TÆRINGARHÆTTA ER MIKIL GILDA ADRAR REGLUR UM STEYPUHULU JÄRNA.

| | PLÖTUR | VEGGIR | BITAR | SÜLUR |
|----------------|--------|--------|-------|-------|
| INNANHÜSS | 15 | 20 | 20 | 20 |
| UTANHÜSS | 25 | 25 | 25 | 25 |
| SÖKKLAR | 35 | 35 | 35 | 35 |
| STEYPT AD JÖRD | 50 | 50 | 50 | 50 |

UM BITA OG SÜLUR GILDIR EINNIG:
C1 ≥ 1.5xd

STEYPUSTYRKARSTÁL
STÁLGEÐI:
K - KAMBSTÁL fyk = 500 Mpa
BEYGING STÁLS
d = ALLIR SVERLEIKAR

SKEYTING BENDISTÁLS ER SAMKVÆMT EFTIRFARANDI: D = 5 x d

| ÞVERMÁL STÁLS, d í mm | 10 | 12 | 16 |
|-----------------------|-----|-----|-----|
| SKEYTIENGD í mm | 500 | 600 | 800 |

LÁRÉTT JÄRN SEM KOMA Í HÖRN EDA ÞVERVEGG SKAL BEYGJA SKEYTIENGD FYRIR HÖRN.

BENDING Í SÖKKULVEGGI
2 K12 EFST OG NEDST
K10 c/c 250 LÖDRÉTT
K10 c/c 300 LÁRÉTT.

MÁL ERU Í mm NEMA ANNARS SÉ GETIÐ.

VERKFRÆÐISTOFA ÁRBORGAR ehf
AUSTURVEGI 69 800 SELFOSSI SÍMI 482 3835 FAX 482 3851

SGHUS
AUSTURVEGI 69 800 SELFOSSI SÍMI 482 3850 FAX 482 3851
NETFANG: sghus@sghus.is
VEFANG: www.sghus.is

BERUSTADIR, ÁSAHREPPÍ

BURDARVIRKI: MKV:
SNID Í SÖKKUL: MKV: 1:20
SKÝRINGAR: MKV:

HANNAÐ: T.ELLERT TÓMASS. TEIKNAD: T.ELLERT TÓMASS.
VERKUNUMÉR: 5063 SKRÁARNAFN: 5063-bv.dwg
DAGSETNING: 20.09.2005 SAMÞYKKT: *[Signature]* TEIKNING NÚMÉR: 202

201170-3979