



STEINSTEYPA
STEYPA ER C25/30 MED A.M.K. 300 Kg SEMENT í m³.

LOFTNINHÁLD STEYPU : 6-8 %
V/S-TALA (UMHVERFISFLOKKUR 2b) : < 0.55
SIGMÁL STEYPU (S2) : 50 - 90 mm
MESTA STEINASTÆRD : 32 mm
TITRA SKAL ALLA STEYPU.

STEYPUHULA Á JÄRNUM
GILDIN EIGA VID UM VENJULEGAR ADSTÆÐUR, EF ANNAD ER EKKI SÝNT Á TEIKNINGUM. ÞAR SEM TÆRINGARHETTA ER MIKIL GILDA ADRAR REGLUR UM STEYPUHULU JÄRNA.

	PLÖTUR	VEGGIR	BITAR	SÚLUR
INNANHÜSS	15	20	20	20
UTANHÜSS	25	25	25	25
SÖKKLAR	35	35	35	35
STEYPT AD JÖRD	50	50	50	50

UM BITA OG SÚLUR GILDIR EINNIG: C1 ≥ 1.5xd

STEYPUSTYRKARSTÁL
STÁLGEÐI: K - KAMBSTÁL fyk = 500 Mpa
BEYGING STÁLS d = ALLIR SVERLEIKAR

SKEYTING BENDISTALS ER SAMKVÆMT EFTIRFARANDI: D = 5 x d

ÞVERMÁL STÁLS, d í mm	10	12	16
SKEYTILENGD í mm	500	600	800

LÁRÉTT JÄRN SEM KOMA Í HORN EDA ÞVERVEGG SKAL BEYGJA SKEYTILENGD FYRIR HORN.

BENDING Í SÖKKULVEGGI
2 K12 EFST OG NEDST
K10 c/c 250 LÖDRÉTT
K10 c/c 300 LÁRÉTT.

MÁL ERU í mm NEMA ANNARS SÉ GETID.

VERKFRÆÐISTOFA ÁRBORGAR ehf
AUSTURVEGI 69 800 SELFOSI SÍMI 482 3835 FAX 482 3851

SGHUS
AUSTURVEGI 69 800 SELFOSI SÍMI 482 3850 FAX 482 3851
NETFANG sghus@sghus.is
VEFFANG www.sghus.is

ÁSHÓLL, RAGNÁRVALLASÝSLU

BURDARVIKRI: MKV:
SNID Í SÖKKUL: MKV: 1:20
SKÝRINGAR OG GRUNDUN: MKV:
HANNAÐ: GÍSLI RAFN TEIKNAD: GÍSLI RAFN
VERKUNUMER: 5042 SKRÁARNAFN: 5042-bv.dwg
DAGSETNING: SMÞYKKT: TEIKNINGUMER:
28.09.2005 202
201170-3979